CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0533:0107

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Viking Corp210 N. Industrial Park Dr, Hastings, MI 49058
Contact: James McKinnon (269) 945-8229 Fax (269) 818-1680
Email: jmckinnon@vikingcorp.com

DESIGN: Model TotalPac2 deluge, single interlock, double interlock, and Fire Cycle III valves in the 1.5", 2", 3", 4" and 6" sizes for use in deluge, pre-action, or Fire Cycle III sprinkler for a rated pressure of 250 psig. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as an accessory for use with Model VFR-400 fire alarm control unit (CSFM Listing No. 7165-0533:106). Refer to listee's Installation Instruction Manual for details.

NOTE:

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011** *Listing Expires* **June 30, 2012**

Authorized By: ***FRANCIS MATEO**, Program Coordinator*

Fire Engineering Division